

1 **QUESTION:**

- 2
- 3 a) Please provide an updated and complete YIS Generation Inventory that includes
4 the rentals (and spares) for 2023-24. Format should be the same as “Appendix A:
5 Existing Resources Technical Attributes” on p. 71 of the 10-Year Renewable
6 Electricity Plan from 2020.

7

8 **ANSWER:**

9

10 **(a)**

11

12 Please see NY-YEC-1-2 Attachment 1 prepared based on 2023/24 GRA assumptions,
13 including new diesel replacements and diesel rentals.

14

15 **Revised Response based on YUB Order 2023-25, Appendix B**

16

17 Board Order 2023-25, section 2(a), finds as follows:

18

19 In respect of IR NY-YEC-1-2(a) and(b) and having considered the submissions in
20 the table in Appendix B, the Board considers the prudence of expenditures and
21 system reliability. YEC’s response to this IR brings into question the reliability of
22 the diesel units under a sustained N-1 condition as no evidence has been provided
23 regarding the changed capacity of all diesel generator units. As a result, the Board
24 directs YEC to provide either documentation or reasons that justify the changing
25 of the dependable capacities for the diesel generator units.

26

27 YEC would like to clarify that in NY’s IRs as filed there was no NY-YEC-1-2(b) – the
28 question referenced as “b” was asked as NY-YEC-1-3(a) and the YEC reply was “Please
29 see the response to NY-YEC-1-2.”

30

31 Board Order 2023-25, Appendix B directs YEC, regarding the changed capacity of all
32 diesel generator units, “to provide either documentation or reasons that justify the
33 changing of the dependable capacities for the diesel generator units”. The change
34 referenced in NY’s reply was increases in dependable capacities for YEC permanent
35 diesel units since the 2021 GRA.

1 (a)

2
3 Please see NY-YEC-1-2 REVISED Attachment 1 prepared based on 2023/24 GRA
4 assumptions, including new diesel replacements and diesel rentals. YEC corrected
5 retirement dates for DD2 and DD5 and also the nameplate capacity for DD3 [from 1,000
6 kW to 1,030 kW].

7
8 As shown in the table below, YEC permanent diesel unit dependable capacities in the
9 2023/24 GRA have increased by approximately 3.0 MW in 2023 and by approximately 2.7
10 MW in 2024 compared with the 10-Year Renewable Electricity Plan dependable capacities
11 used in the 2021 GRA for diesel units not retired by 2023 or 2024. As explained below,
12 these changes in dependable capacities are based on updated assessments by
13 Operations staff.

Location	Original Unit #	Name Plate Capacity (kW)	2021 GRA based on 10-Year Plan Dependable Capacity (kW)	2023/24 GRA 2023/24 F		2023/24 GRA 2024/25 F	
				Dependable Capacity (kW)	Change from 2021 GRA (kW)	Dependable Capacity (kW)	Change from 2021 GRA (kW)
Faro							
Diesel	FD7	3,000	2,800	3,000	200	3,000	200
		3,000	2,800	3,000	200	3,000	200
Dawson							
Diesel	DD1	800	650	850	200	850	200
	DD2	1,000	850	1,000	150		
	DD3	1,030	850	1,030	180	1,030	180
	DD4	1,440	1,000	1,440	440	1,440	440
	DD5	1,500	1,350	1,500	150		
	YM1	1,440	850	1,200	350	1,200	350
		7,210	5,550	7,020	1,470	4,520	1,170
Mayo							
Diesel	MD1	1,000	850	1,000	150	1,000	150
	MD2	1,000	850	1,000	150	1,000	150
	MD3	1,000	850	950	100	950	100
		3,000	2,550	2,950	400	2,950	400
Whitehorse							
Diesel	WD4	2,500	2,250	2,500	250	2,500	250
	WD5	2,500	2,250	2,500	250	2,500	250
	WD6	2,500	2,250	2,500	250	2,500	250
	WD7	3,300	2,800	3,000	200	3,000	200
		10,800	9,550	10,500	950	10,500	950
Total change					3,020		2,720

14
15
16 The increased 2023/24 GRA dependable capacities for existing units resulted from test
17 runs that Operations staff performed on YEC diesel units in 2022 to determine whether

1 the units had limitations. During the test runs issues were found with some of the units
2 and modifications were made as required [under O&M expenses] to bring the units back
3 up closer to nameplate capacity. The change in DD1 dependable capacity in particular
4 reflects the repairs completed due to a failed generator.

5

6 YEC performs test runs and updates dependable capacity on an ongoing basis. YEC is
7 currently finding instances where some of the units have had to be derated again after
8 putting the units through extended runs [for example, DD4].

Dependable Capacity based on YEC's 2023/24 GRA Assumptions

Location	Retirement Year	Original Unit #	Prime Mover Type	Dispatchable	Name Plate Capacity (kW)	2023/24 F	2024/25 F
						Dependable Capacity (kW)	Dependable Capacity (kW)
Aishihik							
Hydro	2050	AH1	hydro	Yes	15,600	15,000	15,000
	2050	AH2	hydro	Yes	15,600	15,000	15,000
	2050	AH3	hydro	Yes	7,000	7,000	7,000
						38,200	37,000
Faro							
Diesel	2050	FD7	diesel	Yes	3,000	3,000	3,000
	2064	New Diesel	diesel	Yes	5,000		5,000
					8,000	3,000	8,000
Dawson							
Diesel	2050	DD1	diesel	Yes	800	850	850
	2024	DD2	diesel	Yes	1,000	1,000	0
	2050	DD3	diesel	Yes	1,030	1,030	1,030
	2050	DD4	diesel	Yes	1,440	1,440	1,440
	2024	DD5	diesel	Yes	1,500	1,500	0
	2050	YM1	diesel	Yes	1,440	1,200	1,200
						7,210	7,020
Mayo							
Diesel	2050	MD1	diesel	Yes	1,000	1,000	1,000
	2050	MD2	diesel	Yes	1,000	1,000	1,000
	2050	MD3	diesel	Yes	1,000	950	950
					3,000	2,950	2,950
Hydro							
Hydro	2050	MH1	hydro	Yes	2,550	1,500	1,500
	2050	MH2	hydro	Yes	2,550		
	2050	MBH1	hydro	Yes	5,310	2,500	2,500
	2050	MBH2	hydro	Yes	5,310	2,500	2,500
					15,720	6,500	6,500
Whitehorse							
Hydro	2050	WH1	hydro	Yes	5,800	3,500	3,500
	2050	WH2	hydro	Yes	5,800	4,138	4,138
	2050	WH3	hydro	Yes	8,400		
	2050	WH4	hydro	Yes	21,327	20,000	20,000
					41,327	27,638	27,638
Natural Gas							
Natural Gas	2055	WG1	Natural Gas	Yes	4,400	4,200	4,200
	2055	WG2	Natural Gas	Yes	4,400	4,200	4,200
	2055	WG3	Natural Gas	Yes	4,400	4,200	4,200
					13,200	12,600	12,600
Diesel							
Diesel	2050	WD4	diesel	Yes	2,500	2,500	2,500
	2050	WD5	diesel	Yes	2,500	2,500	2,500
	2050	WD6	diesel	Yes	2,500	2,500	2,500
	2050	WD7	diesel	Yes	3,300	3,000	3,000
					10,800	10,500	10,500

Location	Retirement Year	Original Unit #	Prime Mover Type	Dispatchable	Name Plate Capacity (kW)	Dependable Capacity (kW)	Dependable Capacity (kW)
----------	-----------------	-----------------	------------------	--------------	--------------------------	--------------------------	--------------------------

YEC Diesel Rentals [excluding spares]

Whitehorse			diesel	Yes	16,200	16,200	16,200
Faro			diesel	Yes	12,600	12,600	12,600
Mayo			diesel	Yes	7,200	7,200	7,200
					36,000	36,000	36,000
Spares			diesel	Yes	3,600	3,600	3,600

AEY Diesel

	CD1	diesel	Yes	1,600	1,200	1,200
	TD1	diesel	Yes	1,500	1,200	1,200
	RD1	diesel	Yes	1,000	750	750
	HD1	diesel	Yes	1,750	1,500	1,500
	Pelly G1	diesel	Yes	275	200	200
	Pelly G2	diesel	Yes	600	400	400
	Pelly G3	diesel	Yes	300	200	200
	Stewart G1	diesel	Yes	150	100	100
				7,175	5,550	5,550

YEC [including rental without spares]	Hydro	95,247	71,138	71,138
	Natural Gas	13,200	12,600	12,600
	Diesel	65,010	59,470	61,970
	Total	173,457	143,208	145,708

AEY Diesel	7,175	5,550	5,550
------------	-------	-------	-------

Yukon Grid	Hydro	95,247	71,138	71,138
	Natural Gas	13,200	12,600	12,600
	Diesel	72,185	65,020	67,520
	Total	180,632	148,758	151,258

N-1 Dependable Capacity [including rental without spares]	Hydro		34,138	34,138
	Natural Gas		12,600	12,600
	Diesel		63,520	66,020
	Total		110,258	112,758

DSM		100	500
Total		110,358	113,258

1 **QUESTION:**

2

3 Please provide the stacking order for thermal generation – two separate lists:

4

5 a) for 2023-24

6

7 b) for 2024-25

8

9 **ANSWER:**

10

11 **(a) and (b)**

12

13 The generation stacking order changes based on available information at the time of
 14 generation, including demand, available resources, system stability requirements, etc.

15

16 The following shows the approximate stacking order of thermal units. The stacking order
 17 for the 2024/25 winter will be revisited closer to the winter of 2024/25 based on available
 18 resources, system stability and condition of thermal units.

19

20 The stacking order is subject to (a) total thermal operation at each site not exceeding air
 21 emissions permit under normal operation conditions and (b) where feasible, maintain each
 22 rental operational hours under 500 hrs/28 days allowance as per contract. It is also
 23 important to note that the thermal units are only run when it is required if the other resource
 24 options are not adequate to meet the demand on the system.

25

Type/ Location	Units	Notes
YEC LNG	WG1, WG2 and WG3	
Whitehorse rentals		
Faro rentals		
Mayo rentals		
YEC Whitehorse diesel	WD4, WD5, WD6, WD7	
YEC Callison diesel	New units	Two 3.25 units potentially available for 2024/25 winter [or 2025/26 winter if delayed]

Type/ Location	Units	Notes
YEC Faro diesel	New units, FD7	Two 2.5 MW new diesel units added for 2024/25 winter
YEC Dawson diesel	DD4, DD3, DD2, DD1	DD2 and DD5 to be retired in 2024
YEC Mayo diesel	MD1, MD2, MD3	

1

2

Revised Response based on YUB Order 2023-25, Appendix B

3

4

Board Order 2023-25, section 2(b), finds as follows:

5

6

7

8

9

In respect of IR NY-YEC-1-04, and having considered the submissions summarized in the table in Appendix B, the Board finds that Mr. Yee's request to put the relevant capacity limits with the stacking order will provide information useful to the Board. Therefore, the Board directs YEC to reproduce the stacking order with the relevant capacity limits for each of the units referenced.

10

11

(a) and (b)

12

13

The generation stacking order changes based on available information at the time of generation, including demand, available resources, system stability requirements, etc.

14

15

16

The following shows the approximate stacking order of thermal units at the time of preparation of the response. The stacking order for the remainder of the 2023/24 winter will be reviewed on an on-going basis and adjusted as considered necessary. The stacking order for the 2024/25 winter will be revisited closer to the winter of 2024/25 based on available resources, system stability and condition of thermal units, and will be adjusted on an on-going basis, as considered necessary.

17

18

19

20

21

22

The stacking order is subject to (a) total thermal operation at each site not exceeding air emissions permit under normal operation conditions and (b) where feasible, maintain each rental operational hours under 500 hrs/28 days allowance as per contract. It is also important to note that the thermal units are only run when it is required if the other resource options are not adequate to meet the demand on the system.

23

24

25

26

27

Type/ Location	Units	Notes
YEC LNG	WG1, WG2 and WG3	Total dependable capacity of 12.6 MW (4.2 MW each unit). See Note 1.
Whitehorse rentals	9 units 1.8 MW each, excluding one spare unit	Total dependable capacity of 16.2 MW. See Notes 1 and 2.
Faro rentals	7 units 1.8 MW each	Total dependable capacity of 12.6 MW. See Notes 1 and 2.
Mayo rentals	4 units 1.8 MW each, excluding one spare unit	Total dependable capacity of 7.2 MW. See Notes 1 and 2.
YEC Whitehorse diesel	WD4 (2.5 MW dependable capacity), WD5 (2.5 MW dependable capacity), WD6 (2.5 MW dependable capacity), WD7 (3 MW dependable capacity)	Total dependable capacity of 10.5 MW. See Note 1.
YEC Callison diesel	New units (two 3.25 MW units = 6.5 MW)	Two 3.25 units potentially available for 2024/25 winter [2023/24 GRA assumes delay to 2025/26 winter]. See Note 1.
YEC Faro diesel	New units (two 2.5 MW units = 5 MW), FD7 (3 MW dependable capacity)	Two 2.5 MW new diesel units added for 2024/25 winter. See Note 1.
YEC Dawson diesel	DD4 (1.440 MW dependable capacity), DD3 (1.030 MW dependable capacity), DD2 (1 MW dependable capacity), DD1 (0.850 MW dependable capacity)	DD2 and DD5 to be retired in 2024. See Note 1.
YEC Mayo diesel	MD1 (1 MW dependable capacity), MD2 (1 MW dependable capacity), MD3 (0.950 MW dependable capacity)	See Note 1.

1 Notes:

- 2 1. Total thermal operation at each site not exceeding air emissions permit under normal
3 operation conditions (total is 13.2 MW for Whitehorse LNG, 16.15 MW for Whitehorse
4 diesel, 15.5 MW for Faro diesel, 7.1 MW for Dawson diesel, 15.5 MW for Callison diesel
5 pending completion of permitting, and 7.9 MW for Mayo diesel including 4.9 MW new
6 permit and 3 MW for Mayo town).
- 7 2. Where feasible, maintain each rental operational hours under 500 hrs/28 days allowance
8 as per contract.

1 The generation stacking order is subject to changes based on available information at the
2 time of generation, including demand, available resources, system stability requirements,
3 etc. The Operations personnel can change the stacking order to respond to the demand
4 on the system and available resources [for example, the staff can elect to run FD7 unit
5 ahead of WD4, WD5 and WD6 units depending on the load on the grid, etc.].

1 REFERENCE: Faro diesel replacement, modifications to the FGS

2
3 QUESTION:


4
5 a) Please provide all plans, layouts, specifications, studies (noise, emissions, etc)
6 and all other documentation relating to the modifications (2023 and 2024) to the
7 FGS. This would also include plans, requirements and instructions given to
8 contractors and subcontractors. Also please provide a list of contractors and
9 subcontractors and RFPs.

10
11 b) Please provide all correspondence between YEC and the Department of
12 Environment concerning the 2023 and 2024 modifications to the FGS.

13
14 ANSWER:

15
16 (a)

17
18 YEC is installing two Tier 4 engines of 2.5MW each. The layout of the site is as follows:



1 Contractors and subcontractors include:

- 2
- 3 • General Contractor (general construction, supervision, mechanical install, civil
- 4 construction) – Wildstone Construction Group;
- 5 • Major Equipment Supplier and Commissioning Agent – Finning;
- 6 • Electrical Subcontractor – Westpark;
- 7 • Tank and mechanical material supplier – Keller;
- 8 • Formwork and reinforcing steel subcontractor – A&T;
- 9 • Concrete supplier – General Enterprises;
- 10 • Concrete finishing subcontractor – JLB;
- 11 • Containment subcontractor – Albarrie;
- 12 • Fencing subcontractor – Olson Fencing.

13

14 **Revised Response for “a” based on YUB Order 2023-25, Appendix B**

15

16 Board Order 2023-25, section (d), finds as follows in respect of IR NY-YEC-1-14(a), and

17 having considered the submissions in the table in Appendix B:

18

19 The Board finds that Mr. Yee’s request is reasonable, and the information

20 requested may be of assistance to the Board. The Board therefore directs YEC to

21 produce a higher resolution copy of the site layout as requested by Mr. Yee.

22 Further, if YEC has the information on the specifications and model number of the

23 generators to the FGS, it shall provide that response to Mr. Yee. If YEC does not

24 have the specifications and model numbers, then it shall confirm that fact.

25

26 **(a)**

27

28 The additional information required from YEC for the two Tier 4 engines of 2.5 MW each

29 that YEC is installing at the FGS is provided below.

30

31 Please see NY-YEC-1-14 REVISED Attachment 1 for a copy of Cat C175-16 Tier 4 Final

32 Product Specifications brochure applicable for these two engines. Please note that the

33 power output of the CATs is 2.5 MW each at a Continuous Rating.

34

35 Please see NY-YEC-1-14 REVISED Attachment 2 for a copy of a high-resolution site

36 layout for the two new diesel units [FD8 and FD9].

1 **(b)**


2

3 The 2023 email thread between T. Ritchie (YEC) and Elizabeth Barker (Yukon
4 Government) regarding the FGS is included as NY-YEC-1-14(b) Attachment 1. The 2023
5 email thread between T. Ritchie (YEC) and Emily Sessford (Yukon Government) is
6 included as NY-YEC-1-14(b) Attachment 2.



Cat® C175-16

Diesel Generator Sets



Bore – mm (in)	175 (6.89)
Stroke – mm (in)	220 (8.66)
Displacement – L (in ³)	84.7 (5167)
Compression Ratio	16.7:1
Aspiration	TA
Fuel System	EUI
Governor Type	ADEM™ A4

Image shown may not reflect actual configuration

Standby 60 Hz ekW (kVA)	Mission Critical 60 Hz ekW (kVA)	Prime 60 Hz ekW (kVA)	Continuous 60 Hz ekW (kVA)	Emissions Performance
3000 (3750)	3000 (3750)	2725 (3406)	2500 (3125)	U.S. EPA Tier 4 Final

Features

Cat® Diesel Engine

- Meets U.S. EPA Tier 4 Final emission standards
- Reliable performance proven in thousands of applications worldwide
- Certified alternative fuels including Hydrotreated Vegetable Oil (HVO), Renewable Diesel (RD) and Hydrotreated Renewable Diesel (HRD) which meet EN 15940 or ASTM D975 can be used or blended with EN 590 diesel

Generator Set Package

- Accepts 100% block load in one step and meets NFPA 110 loading requirements
- Conforms to ISO 8528-5 G3 load acceptance requirements
- Reliability verified through torsional vibration, fuel consumption, oil consumption, transient performance, and endurance testing

Alternators

- Superior motor starting capability minimizes need for oversizing generator
- Designed to match performance and output characteristics of Cat diesel engines

Cooling System

- Cooling systems available to operate in ambient temperatures up to 50°C (122°F)
- Tested to ensure proper generator set cooling

Clean Emissions Module

- Diesel oxidation catalyst for particulate matter (PM) and hydrocarbon (HC) control
- Selective catalytic reduction (SCR) for nitrogen oxides (NOx) control
- Integrated electronics for monitoring, protection, and closed loop NOx control

Cat Energy Control System (ECS)

- User-friendly interface and navigation
- Scalable system to meet a wide range of installation requirements
- Expansion modules and site specific programming for specific customer requirements
- Graphical touchscreen display
- Easily upgradeable

Warranty

- 24 months/1000-hour warranty for standby and mission critical ratings
- 12 months/unlimited hour warranty for prime and continuous ratings
- Extended service protection is available to provide extended coverage options

Worldwide Product Support

- Cat dealers have over 1,800 dealer branch stores operating in 200 countries
- Your local Cat dealer provides extensive post-sale support, including maintenance and repair agreements

Financing

- Caterpillar offers an array of financial products to help you succeed through financial service excellence
- Options include loans, finance lease, operating lease, working capital, and revolving line of credit
- Contact your local Cat dealer for availability in your region



C175-16 Diesel Generator Sets Electric Power

Standard and Optional Equipment

Engine

Air Cleaner

- Single element
- Dual element

Starting

- Standard batteries
- Oversized batteries
- Standard electric starter(s)
- Dual electric starter(s)
- Air starter(s)
- Jacket water heater

Alternator

Output voltage

- 480V 6900V
- 600V 12470V
- 4160V 13200V
- 6300V 13800V
- 6600V

Temperature Rise (over 40°C ambient)

- 150°C
- 125°C/130°C
- 105°C
- 80°C

Winding type

- Form wound

Excitation

- Permanent magnet (PM)

Attachments

- Anti-condensation heater
- Stator and bearing temperature monitoring and protection

Power Termination

Type

- Bus bar
- Circuit breaker
- 4000A 5000A
- UL IEC
- 3-pole
- Electrically operated

Trip Unit

- LSI LSI-G
- LSIG-P

Control System

Controller

- Cat ECS 100
- EMCP 4.4

Attachments

- Local annunciator module
- Remote annunciator module
- Expansion I/O module
- Remote monitoring software

Charging

- Battery charger – 20A
- Battery charger – 35A
- Battery charger – 50A

Vibration Isolators

- Rubber
- Spring
- Seismic rated

Cat Connect

Connectivity

- Ethernet
- Cellular

Extended Service Options

Terms

- 2 year (prime)
- 3 year
- 5 year
- 10 year

Coverage

- Silver
- Gold
- Platinum
- Platinum Plus

Ancillary Equipment

- Automatic transfer switch (ATS)
- Paralleling switchgear
- Paralleling controls

Certifications

- IBC seismic certification
- OSHPD pre-approval

Note: Some options may not be available on all models. Certifications may not be available with all model configurations. Consult factory for availability.

C175-16 Diesel Generator Sets Electric Power




Package Performance

Performance	Standby	Mission Critical	Prime	Continuous
Frequency	60 Hz	60 Hz	60 Hz	60 Hz
Gen set power rating with fan	3000 ekW	3000 ekW	2725 ekW	2500 ekW
Gen set power rating with fan @ 0.8 power factor	3750 kVA	3750 kVA	3406 kVA	3125 kVA
Emissions	Tier 4 Final	Tier 4 Final	Tier 4 Final	Tier 4 Final
Performance number	DM8955-05	EM0315-04	DM8956-04	DM8957-05
Fuel Consumption				
100% load with fan – L/hr (gal/hr)	765.1 (202.1)	765.1 (202.1)	705.0 (186.2)	637.8 (168.5)
75% load with fan – L/hr (gal/hr)	596.7 (157.6)	596.7 (157.6)	558.9 (147.6)	518.0 (136.9)
50% load with fan – L/hr (gal/hr)	451.1 (119.2)	451.1 (119.2)	429.5 (113.5)	396.8 (104.8)
25% load with fan – L/hr (gal/hr)	282.7 (74.7)	282.7 (74.7)	271.2 (71.6)	251.6 (66.5)
Diesel Exhaust Fluid (DEF) Consumption				
100% load with fan – L/hr (gal/hr)	50.7 (13.4)	50.7 (13.4)	45.6 (12.0)	39.2 (10.3)
75% load with fan – L/hr (gal/hr)	30.4 (8.0)	30.4 (8.0)	25.5 (6.7)	22.1 (5.7)
50% load with fan – L/hr (gal/hr)	15.7 (4.1)	15.7 (4.1)	13.8 (3.6)	12.6 (3.2)
25% load with fan – L/hr (gal/hr)	7.4 (2.0)	7.4 (2.0)	6.9 (1.8)	6.5 (1.6)
Cooling System				
Radiator air flow restriction (system) – kPa (in. water)	0.12 (0.48)	0.12 (0.48)	0.12 (0.48)	0.12 (0.48)
Radiator air flow – m ³ /min (cfm)	3188 (112583)	3188 (112583)	3188 (112583)	3188 (112583)
Engine coolant capacity – L (gal)	303.5 (80.2)	303.5 (80.2)	303.5 (80.2)	303.5 (80.2)
Radiator coolant capacity – L (gal)	685.2 (181.0)	685.2 (181.0)	685.2 (181.0)	685.2 (181.0)
Total coolant capacity – L (gal)	988.7 (261.2)	988.7 (261.2)	988.7 (261.2)	988.7 (261.2)
Inlet Air				
Combustion air inlet flow rate – m ³ /min (cfm)	259.3 (9155.0)	259.3 (9155.0)	242.7 (8570.0)	230.5 (8138.0)
Exhaust System				
Exhaust stack gas temperature – °C (°F)	472.3 (882.2)	472.3 (882.2)	460.0 (860.0)	452.7 (846.9)
Exhaust gas flow rate – m ³ /min (cfm)	667.2 (23557.7)	667.2 (23557.7)	610.0 (21540.9)	570.4 (20139.6)
Exhaust system backpressure (maximum allowable) – kPa (in. water)	6.7 (27.0)	6.7 (27.0)	6.7 (27.0)	6.7 (27.0)
CEM outlet temperature – °C (°F)	465.5 (869.9)	465.5 (869.9)	451.1 (844.0)	444.0 (831.2)
Heat Rejection				
Heat rejection to jacket water – kW (Btu/min)	1373 (78075)	1373 (78075)	1229 (69901)	1125 (63972)
Heat rejection to exhaust (total) – kW (Btu/min)	3112 (176964)	3112 (176964)	2796 (159003)	2587 (147112)
Heat rejection to aftercooler – kW (Btu/min)	379 (21574)	379 (21574)	329 (18728)	296 (16810)
Heat rejection to atmosphere from engine – kW (Btu/min)	175 (9978)	175 (9978)	167 (9498)	162 (9237)
Heat rejection to atmosphere from CEM – kW (Btu/min)	53 (3026)	53 (3026)	48 (2756)	45 (2534)
Heat rejection from alternator – kW (Btu/min)	112 (6369)	112 (6369)	99 (5619)	91 (5158)

C175-16 Diesel Generator Sets Electric Power




Weights and Dimensions



Dim "A" mm (in)	Dim "B" mm (in)	Dim "C" mm (in)	Dry Weight kg (lb)
8127 (320.0)	3118 (122.8)	3614 (142.3)	20 463 (45,114)

Note: For reference only. Do not use for installation design. Contact your local Cat dealer for precise weights and dimensions.



Dim "A" mm (in)	Dim "B" mm (in)	Dim "C" mm (in)	Dry Weight kg (lb)
4579 (180.3)	2361 (92.9)	1735 (68.3)	2900 (6393)

Ratings Definitions

Standby

Output available with varying load for the duration of the interruption of the normal source power. Average power output is 70% of the standby rated kW. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year.

Mission Critical

Output available with varying load for the duration of the interruption of the normal source power. Average power output is 85% of the mission critical rated kW. Typical peak demand up to 100% of rated kW for up to 5% of the operating time. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year.

Prime

Output available with varying load for an unlimited time. Average power output is 70% of the prime rated kW. Typical peak demand is 100% of prime rated kW with 10% overload capability for emergency use for a maximum of 1 hour in 12. Overload operation cannot exceed 25 hours per year.

Continuous

Output available with non-varying load for an unlimited time. Average power output is 70-100% of the continuous rated kW. Typical peak demand is 100% of continuous rated kW for 100% of the operating hours.

Applicable Codes and Standards

AS 1359, UL 489, UL 869A, IBC, IEC 60034-1, ISO 3046, ISO 8528, NEMA MG1-22, NEMA MG1-33, 2014/35/EU, 2006/42/EC, 2014/30/EU and facilitates compliance to NFPA 37, NFPA 70, NFPA 99, NFPA 110.

Note: Codes may not be available in all model configurations. Please consult your local Cat dealer for availability.

Data Center Applications

- All ratings Tier III/Tier IV compliant per Uptime Institute requirements.
- All ratings ANSI/TIA-942 compliant for Rated-1 through Rated-4 data centers.


Fuel Rates

Fuel consumption reported in accordance with ISO 3046-1, based on fuel oil of 35° API [16°C (60°F)] gravity having an LHV of 42,780 kJ/kg (18,390 Btu/lb) when used at 15°C (59°F) and weighing 850 g/liter (7.0936 lbs/U.S. gal.) All fuel consumption values refer to rated engine power.

www.cat.com/electricpower

©2023 Caterpillar
 All rights reserved.

Materials and specifications are subject to change without notice. The International System of Units (SI) is used in this publication.



REFERENCE DRAWINGS	
DWG. NO.	DRAWING TITLE
FD0-D-E310-2	ELECTRICAL SITE PLAN CONDUIT SCHEDULE
FD0-D-E315-1	FD8/FD9 ELECTRICAL SECTION VIEWS (SHT. 1)
FD0-D-E315-2	FD8/FD9 ELECTRICAL SECTION VIEWS (SHT. 2)

- NOTES**
- CABLE BUS SUPPORT SPANS SHOWN AS 3.048m [10ft]. MAXIMUM SUPPORT SPAN ON STRAIGHT RUNS SHOULD NOT EXCEED 3.65m PER CABLE BUS MANUFACTURER RECOMMENDATIONS.
 - A 10ft x 10ft SQUARE AROUND THE ARC EXHAUST POINT OF THE FDO SWITCHGEAR MODULE SHALL BE MARKED WITH CURBSTONES (OR SIMILAR) AND WITH APPROPRIATE SIGNAGE PLACED ON THE WALL OF THE SWITCHGEAR MODULE UNDERNEATH THE ARC EXHAUST POINT TO WARN PERSONNEL TO AVOID ENTERING THE AREA. DETAILS OF THE MARKING & SIGNAGE ARE TO BE FINALIZED BY WILDSTONE.
 - CONDUIT FOR ZIG-ZAG TRANSFORMER TO STUB-UP THROUGH FLOOR OPENING SHOWN. CABLE WILL BE ROUTED IN CONDUIT/TRAY FROM STUB-UP INTO ZIG-ZAG TRANSFORMER. DETAILS TO BE FINALIZED AND COORDINATED WITH FINNING.
 - LOCATION OF FDO-SST4 HAS BEEN SHIFTED SOUTH PER YEC COMMENTS; CONDUIT + TRANSFORMER VAULT INSTALLATION AND EXACT LOCATION TO BE FIELD-FIT ONSITE.
 - FOR CABLE BUS SECTION VIEW DRAWINGS, PLEASE REFER TO MPHUSKY CABLE BUS DRAWING PACKAGE.
 - RENTAL GENERATOR EQUIPMENT LOCATIONS AND CABLE ROUTING NOT SHOWN.

ISSUED FOR CONSTRUCTION
(BELOW GRADE ONLY)

StruthersTECH
#3 - 1101 Main Street, Penticton, BC, V2A 5E6
www.strutherstech.com

REV.	DATE	DESCRIPTION	BY	DES.	APP.
0	MAY 26 2023	ISSUED FOR CONSTRUCTION (BELOW GRADE ONLY)	RB	RB	

<p>COMPANY PERMIT</p> <p>PERMIT TO PRACTICE STRUTHERS TECHNICAL SOLUTIONS LTD. SIGNATURE: <i>Ryan Bentley</i> Date: May 26, 2023 PERMIT NUMBER PP482 Association of Professional Engineers of Yukon</p>	<p>ENGINEERS STAMP</p> <p>PROFESSIONAL YUKON TERRITORY ENGINEER R.M. BENTLEY May 26, 2023</p>
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------

YUKON ENERGY CORPORATION

THERMAL REPLACEMENT PROJECT

<p>CHECKED BY B. STAHL</p> <p>DATE MAY 26/23</p> <p>DRAWN BY R. BENTLEY</p> <p>SCALE 1:167</p>	<p>FARO DIESEL PLANT FD8 & FD9 ELECTRICAL SITE PLAN</p>	<p>SCALE A1</p>	<p>REV. 0</p>
----------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------	---------------------	-------------------

DETAIL A
SCALE: 1:100
E310-1

CABLE BUS ROUTING DETAILS

DETAIL B
SCALE: 1:100
E310-1

FUEL SYSTEM CABLE TRAY DETAILS